


Information

Notes

SpiralOne has a valve controlled by pass for greater efficiency. This ensures complete separation of the hot flow and cooler return water within the manifold. Because of this, a standard spring loaded Non-return valve is required on each circuit connected to a SpiralOne.

This schematic shows the key components in the mechanical system and the list of materials shown is non-exhaustive. All systems should be installed in accordance with building regulations and by a qualified installer.

The schematic is a representation of a heating system and Systemlink will not be held responsible for any errors shown.



LEGEND

- | | | | |
|--|--------------------------|--|------------------------|
| | Motorised Valve | | Direction Arrow |
| | Isolating Valve | | Strainer |
| | Safety Valve | | DW Pressurisation Pump |
| | Non Return Valve | | Drain Cock |
| | Temperature Relief Valve | | Circulating Pump |
| | By-pass Valve | | |
| | Flow Regulating Valve | | |
| | Pressure Reducing Valve | | |
| | Automatic Air Valve | | |
| | Pressure Gauge | | |
| | Temperature Gauge | | |
| | Temperature Sensor | | |

Example: Heating Schematic
Ref: Midland Renewables

Unit 1 Greenhills Business Park,
Tallaght, Dublin 24

Tel: 00-353-(0)1 4031200
Fax: 00-353-(0)1 4137777
email: info@systemlink.ie
email: info@systemlink.co.uk

systemlink
ENERGY SAVING SOLUTIONS

Scale: NTS

Rev: 001

Drawn: CC

26.11.14