


## Isolated Power Supply

'Lex-Links' already exist on the SystemLex and need not be installed

' Installer-Links ' MUST be fitted by the installing engineer



The volt free relay 72-73 is closed when activated by 81 or / and 82.

The volt free relay 63-64 is closed when activated by 14 or / and 24.

**SystemLink Ltd.**  
C2 South City Business Centre,  
Tallaght, Dublin 24  
Tel: 00-353-(0)1 4031200  
Fax: 00-353-(0)1 4137777  
e:mail: info@systemlink.ie

Ref: RN Murphy

## Scale: NTS

Rev: 009

Drawn: AK

Date: 05-03-09

To aid diagram clarity, EARTH connections are not shown but must be installed in accordance with manufacturers instructions