


Information

Notes

Non-return valves are required on Systemlink's outward zone flow pipe-work only when the zone to be piped is at a higher level than the Systemlink. In that situation, a non-return valve must be positioned in front of the zone pump. This will prevent the creation of a gravity fed, thermo-siphoning loop, which would cause continued supply of heated water to the radiators in that zone, even when the zone's pump is no longer required and has been switched off.

This schematic shows the key components in the mechanical system and the list of materials shown is not exhaustive. All systems should be installed by a qualified installer and should be installed in accordance with building regulations. Systemlink will not be held responsible for any errors shown in the schematic.



LEGEND

| | | | | | |
|--|---------------------------|--|------------------------|--|---------------------|
| | Motorised Valve | | Oil Tank Filter | | Gas Slam Valve |
| | Isolating Valve | | Strainer | | Binder Test Point |
| | Safety Valve | | DW Pressurisation Pump | | Direction Arrow |
| | Non Return Valve | | Drain Cock | | Hi-Pressure Switch |
| | Pressure Relief Valve | | Circulating Pump | | Low Pressure Switch |
| | Oil Fire Slam Valve | | | | |
| | Temperature Relief Valve | | | | |
| | Pressure Regulating Valve | | | | |
| | Flow Regulating Valve | | | | |
| | Pressure Reducing Valve | | | | |
| | Temperature Mixing Valve | | | | |
| | Automatic Air Valve | | | | |
| | Pressure Gauge | | | | |
| | Temperature Gauge | | | | |
| | Temperature Sensor | | | | |

Example: Heating Schematic
1 Gas Boiler, 3 Underfloor Zones, 1 DHW Zone

Systemlink
C2 South City Business Centre,
Tallaght, Dublin 24
Tel: 00-353-(0)1 4031200
Fax: 00-353-(0)1 4137777
e-mail: info@systemlink.ie
e:mail, info@systemlink.co.uk

Scale: NTS

Rev: 001

Drawing No. 01000310