


Information

Note

Non-return valves are required on System-link's outward zone flow pipe-work only when the zone to be piped is at a higher level than the System-link. In that situation, a non-return valve must be positioned in front of the zone pump. This will prevent the creation of a gravity fed, thermo-siphoning loop, which would cause continued supply of heated water to the radiators in that zone, even when the zone's pump is no longer required and has been switched off.



LEGEND

- 
- 
- 
- 
- 

Example: Heating Schematic

Ref: Paddy Dempsey

Systemlink

C2 South City Business Centre,  
Tallaigh, Dublin 24  
Tel: 00-353-(0)1 4528301  
Fax: 00-353-(0)1 4137777  
email, info@systemlink.ie

Scale: NTS

Rev: 001

Drawn: AK

Date: 07-07-08