


Information

Note

Non-return valves are required on System-link's outward zone flow pipe-work only when the zone to be piped is at a higher level than the System-link. In that situation, a non-return valve must be positioned in front of the zone pump. This will prevent the creation of a gravity fed, thermo-siphoning loop, which would cause continued supply of heated water to the radiators in that zone, even when the zone's pump is no longer required and has been switched off.



LEGEND

- | | | | | | |
|--|-----------------------|--|---------------------------|--|--------------------------|
| | Motorised Valve | | Oil Fire Slam Valve | | Temperature Mixing Valve |
| | Isolating Valve | | Temperature Relief Valve | | Automatic Air Valve |
| | Safety Valve | | Pressure Regulating Valve | | Pressure Gauge |
| | Non Return Valve | | Flow Regulating Valve | | Temperature Gauge |
| | Pressure Relief Valve | | Pressure Reducing Valve | | Temperature Sensor |
| | Oil Tank Filter | | Strainer | | DW Pressurisation Pump |
| | Gas Slam Valve | | Drain Cock | | Circulating Pump |
| | Binder Test Point | | Direction Arrow | | Hi-Pressure Switch |
| | Low Pressure Switch | | | | |

Example: Heating Schematic

SystemLink

C2, South City Business Park,
Tallaght, Dublin 24
Tel: 00-353-(0)1 4528301
Fax: 00-353-(0)1 4137777
e:mail, info@systemlink.ie

Scale: NTS

Rev: 001

Drawn: AK

Date: 02/01/08