

Information

the zone's pump is no longer required and to the radiators in that zone, even when fed, thermo-syphoning loop, which would This will prevent the creation of a gravitu be positioned in front of the zone pump. is at a higher level than the SystemLink. plpe-work only when the zone to be piped cause continued supply of heated water In that situation, a non-return valve must System Ink's outward zone flow Non-return valves are required on

any errors shown in the schematic. Systemlink will not be held responsible for in accordance with building regulations. qualified installer and should be installed All systems should be installed by a in the mechanical system and the list of materials shown is not exhaustive. This schematic shows the key components has been switched off.

Example: Heating Schematic 1 Gas Boiler, 2 Radiator ZoneS, 1 Underfloor Zone, 1 DHW Zone

Motorised Valve

I Isolating Valve

Safety Valve

Oil Fire Slam Valve

Pressure Refief Valve Non Return Valve

4

Temperature Sensor Temperature Guage Pressure Guage Automatic Air Valve Temperature Mixing Valve

Drain Cock
Circulating Pump

H-s \triangleleft

Hi-Pressure Switch Direction Arrow

Low Pressure Switch

Scale: NTS

Rev: 001

Strainer

DW Pressurisation Pump Oil Tank Filter

Mo

Binder Test Point Gas Slam Valve

Pressure Regulating Valve ➤ Pressure Reducing Valve

Pressure Regulating Valve Temperature Relief Valve

Drawing No. 01002110 e:mail, info@systemlink.co.uk C2 South City Business Centre, e:mail, info@systemlink.ie Fax: 00-353-(0)1 4137777 Tel: 00-353-(0)1 4031200 Tallaght, Dublin 24

SystemLink

